



**PUBLIC PROTECTION CABINET  
Department of Housing, Buildings and Construction  
Division of Fire Prevention**

500 Mero Street, First Floor  
Frankfort, KY 40601  
Phone: 502-573-1702 Fax: 502-573-1695

**Ray A. Perry  
Secretary**

**Max Fuller  
Commissioner**

**David Moore  
Deputy Commissioner**

**Andy Beshear  
Governor**

**Jacqueline Coleman  
Lieutenant Governor**

April 24, 2025

**XL Industrial Services Inc**

XL Industrial Services, Inc  
3920 Kramers Lane  
LEXINGTON, KY 40504

**RE: Permit #: PLP000200**

Marathon Petroleum Logistics  
4510 Algonquin Pkwy  
Louisville, KY - Jefferson  
1- 89,800 gallon butane AGST, associated steel  
product piping  
**HazMat Plan Review Approved with Conditions**

Dear Sir or Madam:

The Hazardous Materials Section of the Division of Fire Prevention is pleased to advise you that the site plans and specifications for the installation of the above referenced items have been approved for the above referenced location providing that the following condition(s) are met:

**The connection or line that leads to or from any individual opening shall have a flow capacity greater than the rated flow of the excess-flow valve.**

**NFPA 58- 2017 edition, section 5.9.8.1(H)**

**Hydrostatic relief valves shall be provided in sections of liquid piping that can be isolated with shutoff valves.**

**NFPA 58- 2017 edition, section 6.15**

**Visible hazard identification signs in accordance with NFPA 704 shall be placed at the following locations, except where the AHJ has received a hazardous materials management plan and a hazardous materials inventory statement in accordance with 60.1.6 and 60.1.7 and has determined that omission of such signs is consistent with safety:**

- (1) On stationary aboveground tanks**
- (2) On stationary aboveground containers**
- (3) At entrances to locations where hazardous materials are stored, dispensed, used, or handled in quantities requiring a permit**
- (4) At other entrances and locations designated by the AHJ**

**NFPA 1- 2018 edition, section 60.5.1.8.2.1**

As soon as you receive this approval, it is your responsibility to contact your Hazardous Materials Inspector denoted below to review the scope of the job, schedule testing and assist with any questions. If you are unable to make contact with the assigned inspector, please contact the Hazardous Materials Section at the numbers above.

Failure of this office to note all violations during the review of plans and specifications does not relieve the installation contractor of the responsibility for complying with all applicable codes and regulations. Please contact your local officials to determine the necessity for other permits. Electrical wiring installations are required to be approved by the Certified Electrical Inspector.

Failure to follow these instructions could result in actions against the installation contractor and/or any associated certifications or licenses. If you have any questions or concerns, please contact the Hazardous Materials Section at the numbers above.

Sincerely,

Dale Mancuso FM76

Division of Fire Prevention

Permit Expiration Date: 10/21/2025

ASSIGNED INSPECTOR: Dale Mancuso FM76, Email: dale.mancuso@ky.gov, Phone: 502-526-6658