From: Joe Elstone
To: Brooks, Amy
Subject: 24-ZONE-0137 Billtown complex
Date: Monday, November 18, 2024 3:10:49 PM

CAUTION: This email came from outside of Louisville Metro. Do not click links, open attachments, or give away private information unless you recognize the sender's email address and know the content is safe.

Amy-

I was contacted by a developer on this project. Below are the comments I emailed to her:

My comments for the Billtown Rd project:

1. *Multiple fire hydrants will be needed*
2. *The apartment buildings will need a fire sprinkler system. The fire dept connection for each building will be a single, 2.5-inch, female inlet with national standard threads.*
3. *A Knox Box will be required for the apartment complex. Location of box can be determined later but it will need to be near the main entrance to the complex.*

I believe Jeffersontown may have also received a request on this project. This project is 90%+ in my district so I will handle all reviews.

Thx

Major Joseph Elstone
Fern Creek Fire & EMS
4101 Bardstown Rd.
Louisville, Ky. 40291
502.239.7075